



Test Report issued under the responsibility of:



TEST REPORT IEC 60947-5-1 Part 5: Control circuit devices and switching elements Electromechanical control circuit devices	
Report Number	00901-CB201600C-071333
Date of issue	2016-05-30
Total number of pages	42
CB Testing Laboratory	Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)
Address	505 Wu Ning Road Shanghai P. R. China
Applicant's name	Zhejiang Tengen Electrics Co., Ltd.
Address	TENGEN Industry Zone, Liushi, Yueqing City, Zhejiang Province, P.R. China
Test specification:	
Standard	IEC 60947-5-1: 2003 (3rd Edition) + A1:2009
Test procedure	CB Scheme
Non-standard test method	N/A
Test Report Form No.	IEC60947_5_1D
Test Report Form(s) Originator	KEMA Quality BV
Master TRF	Dated 2010-01
Copyright © 2010 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
Test item description	Auxiliary Contacts
Trade Mark	TENGEN
Manufacturer	Zhejiang Tengen Electrics Co., Ltd./ TENGEN Industry Zone, Liushi, Yueqing City, Zhejiang Province, P.R. China
Model/Type reference	OF
Ratings	Ui: 415V; Ith: 6A; AC-12: Ue/Ie: AC415V/3A, AC240V/6A; DC-12: Ue/Ie: DC130V/1A, DC48V/2A, DC24V/6A;

Testing procedure and testing location:		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)
Testing location/ address		505 Wu Ning Road Shanghai P. R. China
<input checked="" type="checkbox"/>	Associated CB Laboratory:	
Testing location/ address		505 Wu Ning Road Shanghai P. R. China
Tested by (name + signature)		Yin Jifu 阴吉福
Approved by (name + signature)		Wei Qingyuan 魏庆媛
<input type="checkbox"/>	Testing procedure: TMP	
Testing location/ address		
Tested by (name + signature) :		
Approved by (+ signature)		
<input type="checkbox"/>	Testing procedure: WMT	
Testing location/ address		
Tested by (name + signature) :		
Witnessed by (+ signature) :		
Approved by (+ signature) :		
<input type="checkbox"/>	Testing procedure: SMT	
Testing location/ address		
Tested by (name + signature) :		
Approved by (+ signature)		
Supervised by (+ signature)		
<input type="checkbox"/>	Testing procedure: RMT	
Testing location/ address		
Tested by (name + signature) :		
Approved by (+ signature)		
Supervised by (+ signature)		