



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200303007053

Product Moulded Case Circuit-breakers

Applicant Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TeM5ED-125L,TeM5ED-125M,TeM5ED-125H,TeM5ED-2
50L,TeM5ED-250M,TeM5ED-250H

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2020CQC0303-011350, the submitted sample(s) of the above item complies
with:

EN60947-2:2017

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Dec.09,2020

Valid until: Dec.09,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010973



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE200303007053

TeM5ED-125L, TeM5ED-125M, TeM5ED-125H,
TeM5ED-250L, TeM5ED-250M, TeM5ED-250H;

Uimp:8kV;

Ui:1000V;

Ue:AC380V/AC400V/AC415V;

In:

63-125A (adjustable) (TeM5ED-125L, TeM5ED-125M, TeM5ED-125H);

100-250A (adjustable) (TeM5ED-250L, TeM5ED-250M, TeM5ED-250H);

Over-current release: electronic;

Ics:35kA(L),50kA(M),65kA(H) ;

Icu:50kA(L,M),85kA(H) ;

Selectivity category: A;

3P,3P+N(3 protected poles with an uninterrupted neutral pole);

50Hz/60Hz;

Applicable for isolation(except for 3P+N);

IP20 (except for the terminals);

Auxiliary contact and alarm contact:

OF-M, SD-M;

1NO1NC, 2NO2NC, 4NO4NC;

Ith: 3A;

AC-15:Ue/Ie:AC380V/AC400V/AC415V/0.3A;

DC-13:Ue/Ie:DC110V/DC220V/DC250V/0.15A

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>