



Ref. Certif. No.

HU-003885

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Air Circuit Breaker
Name and address of the applicant	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the manufacturer	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the factory	Zhejiang Tengen Electric Co., Ltd. (Yueqing Economic Development Zone Branch) No.288 Central Avenue, Development Zone, Yueqing City, 325604 Zhejiang, P.R. China
Ratings and principal characteristics	Cat. B; Type of Release: Electronic; 3P, 4P; Ue=AC 415/690V, 50/60Hz; Ui=1000V; Uimp=12.0kV; In: 4000A, 4900A, 5000A, 5900A, 6300A; Ics=Icu: 120kA for AC 415V, 85kA for AC 690V; Icw: 100kA/s for AC 415V, 80kA/s for AC 690V
Trademark (if any)	Tengen (Logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	TGW1N-6300
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN227XP2 001.
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN227XP2 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2022-04-29

Signature: Wencai Zhang