



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230305008250

Product Thermal overload relay

Applicant Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TGR1-95,TGRH-95,TGRK-95,TGR1-100,TGRH-100,TGR
K-100;

Technical data Uimp:6kV;Ui:690V;Ue:AC690V;TGR1-95,TGRH-95,TGR
K-95:Ie:23~32A,30~40A,37~50A,48~65A,55~70A,63~80A,
80~95A;
TGR1-100,TGRH-100,TGRK-100:Ie:23~32A,30~40A,37~5
0A,48~65A,55~70A,63~80A,80~95A,86~100A; Tripping
class:10A;3P;IP20; Auxiliary
contacts:1NO,1NC;Ith:5A;AC-15:Ue/Ie:220V/1.64A,380V/0
.95A;DC-13:Ue/Ie:220V/0.15A

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2024CQC0305-014393, the submitted sample(s) of the above item complies
with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jan.23,2024

Valid until: Jun.01,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE