

CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE250305009691

Product AC contactor

Applicant Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TGCA-4011,TGCA-4011N,TGCA-5011,TGCA-5011N,TGC
A-6511,TGCA-6511N

Technical data See the attachment

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-25D0036-S, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jul.01,2025

Valid until: Jun.30,2028

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE250305009691

TGCA-4011, TGCA-4011N, TGCA-5011, TGCA-5011N,
TGCA-6511, TGCA-6511N
Ui:690V;Uimp:6kV;
Ith: TGCA-4011, TGCA-4011N: 60A;
TGCA-5011, TGCA-6511, TGCA-5011N, TGCA-6511N: 80A;
AC-1:
TGCA-4011, TGCA-4011N:
Ue/le:220V/230V;380V/400V/60A;
TGCA-5011, TGCA-6511, TGCA-5011N, TGCA-6511N :
Ue/le:220V/230V;380V/400V/80A;
AC-3:
TGCA-4011:Ue/le:220V/230V/40A;380V/400V/40A; 660V/690V/34A;
TGCA-5011 :Ue/le: 220V/230V/50A;380V/400V/50A;
660V/690V/39A;
TGCA-6511 :Ue/le: 220V/230V/65A;380V/400V/65A;
660V/690V/42A;
AC-4:
TGCA-4011, TGCA-4011N:
Ue/le:220V/230V/18.5A;380V/400V/18.5A;
660V/690V/9A;
TGCA-5011, TGCA-5011N :
Ue/le:220V/230V/24A;380V/400V/24A;660V/690V/12A;
TGCA-6511, TGCA-6511N:
Ue/le:220V/230V/28A;380V/400V/28A;660V/690V/14A;
Us: AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,
AC400V,AC415V,50Hz;
AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,
AC400V,AC415V, 50/60Hz;
Utilization category: AC-1, AC-3,AC-4;
Number of poles:3P;
IP20;
Attached auxiliary contact: 1NO,1NC,2sets;
Ith:10A;Ui:690V;Uimp:6kV;
AC-15:1.6A/220V,0.95A/380V,
DC-13:0.15A/220V



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE